


Candidate DER Functions

June 21, 2013 10:45 to 12:00



Phase 1: Autonomous DER Systems in a Customer or Utility Site


No external communications are involved, just internal communications between the controller and the physical device



- Data models are proprietary and specific to the type of device and the manufacturer
- ModBus is the protocol used by most inverter manufacturers for internal communications
- ModBus has no intrinsic cybersecurity, but may be embedded as payload in secure messages

Level 2: Facilities DER Energy Management System (FDEMS) to Manage Groups of DER Systems

FDEMS communicate with DER controllers to monitor, control, or request actions. May include multiple layers of DER Management systems.




- IEC 61850-7-420/90-7 Information Models should be used between the DER controllers and the Facilities Energy Management Systems
- ModBus is predominantly used, while alternative protocols include SEP 2.0, OPC/UA, and BACnet.
- MMS (61850-8-1) may be used in Europe


Candidate Phase 1 Mandatory Autonomous DER Functions

- Support anti-islanding to trip off under extended anomalous conditions
- Provide ride-through of low/high voltage excursions beyond normal limits (L/HVRT)
- Provide ride-through of low/high frequency excursions beyond normal limits (L/HFRT)
- Provide volt/var control by dynamic reactive power injection through autonomous responses to local voltage measurements (VV)
- Counteract frequency excursions beyond normal limits by decreasing or increasing real power (FW)
- Counteract voltage excursions beyond normal limits by providing dynamic current support
- Reconnect randomly within a preset time window after grid power is restored
- Limit maximum real power output at the PCC to a preset value
- Modify real power output autonomously in response to local voltage variations
- Provide reactive power by a fixed power factor
- Set actual real power output at the PCC
- Schedule actual or maximum real power output at specific times


Voltage Ride-Through Settings




Volt-Var Control Function



Frequency-Watt Function



Phase 2: DER Systems with Communications



Candidate Phase 2 Mandatory DER Functions with Communications

- Communication requirements:
 - Provide capability for adding modules for different media interfaces
 - Provide the TCP/IP internet protocols
 - Use the IEC 61850 information model for defining data exchanges
 - Support the mapping of the IEC 61850 information model to DNP3
 - Provide cyber security with user and device authentication
- Communications used primarily for updating autonomous settings
- Communications for situational awareness and control:
 - Provide emergency alarms and information
 - Provide status and measurements on energy and ancillary services
 - Limit maximum real power output at the PCC upon a direct command from the utility

Phase 1 Recommended Autonomous DER Functions

- The following DER functions are recommended but not mandated:
 - Smooth minor frequency deviations by rapidly modifying real power output to these deviations
 - Follow schedules for energy and ancillary service outputs
 - Set or schedule the storage of energy for later delivery, indicating time to start charging, charging rate and/or "chargeby" time

Phase 2 Recommended DER Functions with Communications

- The following DER functions are recommended but not mandated:
 - Support direct command to disconnect or reconnect
 - Provide operational characteristics at initial interconnection and upon changes
 - Test DER software patching and updates